

Certificate
2605723 (1)



Issued 10/06/2026
Valid until 10/06/2031

Kiwa UK Regulation 4 (KUKreg4) Approval

Kiwa hereby declares that legitimate confidence exists in the products specified and model number(s) listed in the Appendix for:

Genebre S.A.

meets the requirements as described in the
Evaluation Guideline – Kiwa UK – EG004 (Issue 7) – Regulation 4(1)(a)

Which verifies the requirements of reference standard(s):

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification and is only valid in combination with the appendix.

David Jay
Business Unit Manager- Authorised
Signatory Kiwa Limited (Watertec)

This certificate relates to products intended to be used in the UK only. For other countries, other (National) requirements will apply.

Disclosure of the certificate is permitted in full.

To check the validity of a certificate, scan the QR code or go to <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/>



KUKreg4

Appendix

The following products belong to this certificate

PRODUCT DESCRIPTION Range of full port ball valves incorporating stainless steel bodies and balls, with a single lever operating member. ATS3 – Without Production Surveillance.
MODEL(S) 2015 02 – 1/4" 2015 03 – 3/8" 2015 04 – 1/2" 2015 05 – 3/4" 2015 06 – 1" 2015 07 – 1 1/4" 2015 08 – 1 1/2" 2015 09 – 2"
SIZE: See model
SCOPE: Manufacturer recommended maximum working pressure 63 Bar & maximum operating temperature cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
MARKING Genebre logo, size and pressure on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge
BACKFLOW PROTECTION NOTES N/A
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes