

Certificate 2607702 (1)



Issued 29/07/2026
Valid until 29/07/2031

Kiwa UK Regulation 4 (KUKreg4) Approval

Kiwa hereby declares that legitimate confidence exists in the products specified and model number(s) listed in the Appendix for:

Genebre S.A.

meets the requirements as described in the
Evaluation Guideline – Kiwa UK – EG004 (Issue 7) – Regulation 4(1)(a)

Which verifies the requirements of reference standard(s):

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification and is only valid in combination with the appendix.

David Jay
Business Unit Manager- Authorised
Signatory Kiwa Limited (Watertec)

This certificate relates to products intended to be used in the UK only. For other countries, other (National) requirements will apply.

Disclosure of the certificate is permitted in full.

To check the validity of a certificate, scan the QR code or go to <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/>



Appendix

The following products belong to this certificate

PRODUCT DESCRIPTION Range of wafer type butterfly valves with blue epoxy coated ductile iron bodies, zinc plated iron discs and lever type operating member. ATS3 – Without Production Surveillance.
MODEL(S) 2109 09 - 2" 2109 10 - 2 1/2" 2109 11 - 3" 2109 12 - 4" 2109 13 - 5" 2109 14 - 6" 2109 16 - 8" 2109 18 - 10"
SIZE: See model
SCOPE: Manufacturer recommended maximum working pressure 16.0 Bar & maximum operating temperature cold water use only Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
MARKING Genebre, PN and other technical information on data plate on body. Genebre, DN and PN on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge
BACKFLOW PROTECTION NOTES N/A
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements

Extra Notes